

1. Are single line drawings available showing the electrical information of the suggested point of interconnection? Alternatively, a description would be just as helpful.

We will retrieve single line drawings once the quarantine is lifted.

2. Will tree trimming/removal be permitted?

Yes, some trimming and removal may be necessary.

3. Please provide utility bills and/or rates for all facilities listed in the RFP.

All in rate is 13 cents per kWh. The total kWh for each facility is noted in RFPS. The annual kWh of each facility was reduced by 20 percent to account for future energy conservation projects.