



**TOWNSHIP OF MONROE
BUREAU OF FIRE PREVENTION**

125 Virginia Ave.
Williamstown, NJ 08094-1768
856-728-9800 Ext. 256
856-875-2941 (Fax)

To whom it may concern,

Be advised that any Food Truck that will be cooking at any event in Monroe Township, shall be required to meet the requirements of the State of New Jersey Fire Code N.J.A.C 5:71-2.2 or UFC 2015 NJ Edition.

All Mobile trucks that have a cooking area or a deep fryer must have a certified and inspected range hood fire suppression system installed. They must have a (K) type fire extinguisher with a current inspection tag.

Any other heating equipment for baking or warming must have an "ABC" 5 LB Fire extinguisher with a current inspection tag.

All LPG gas systems will be checked for proper fuel hoses or piping and an up to date hydro test stamp.

Any system found to be in violation will not be permitted to be used.

No vehicle will be permitted to operate without the proper equipment.

Skip Tomarchio, Fire Marshal

Township of Monroe

APPLICATION FOR PERMIT

LOCATION INFORMATION

MUNICIPAL CODE:		REGISTRATION #:	
NAME:		STREET ADDRESS:	
MUNICIPALITY:		COUNTY:	
STATE:	ZIP CODE:	AREA CODE & PHONE #:	

APPLICANT INFORMATION

APPLICANT'S NAME:		APPLICANT'S HOME STREET ADDRESS:	
MUNICIPALITY:		COUNTY:	
STATE:	ZIP CODE:	PHONE #:	FAX #:

[] Permit requested for following date(s) : _____

[] Permit requested for one year - Expiration Date: _____

NOTE: Attach additional signed sheet if space is insufficient

The above named applicant hereby requests permission to conduct the following activity at the above location:

And / or for the storage, occupancy, use, sale, handling or manufacturing of the following:

State quantities and method for each category or material to be stored or used:

I hereby acknowledge that the information given is correct, and agree to comply with the applicable requirements of the New Jersey Uniform Fire Code as well as any specific conditions imposed, and, if not, this permit may be revoked and I will be subject to penalties as provided by law.

Applicant's Signature

Title
**MONROE TOWNSHIP BUREAU
OF FIRE PREVENTION**
125 Virginia Ave. Suite #5
Williamstown, NJ 08094

Date

MAKE CHECK PAYABLE TO _____

AND MAIL TO:

FOR OFFICIAL USE ONLY

Permit Type: <u>1</u>	[] Conditions Imposed	[] Denied	[] Approved pending payment of \$ <u>574.00</u>	Fee **
-----------------------	------------------------	------------	--	--------

5:71-3.7(b)12.

Fire Official Signature

ype 1 Permit - \$ 54.00

- . Bonfires;
 - . The use of a torch or flame-producing device to remove paint from, or seal membrane roofs on, any building or structure;
 - . The occasional use of any non-residential occupancy other than Use Groups F, H or S for group overnight stays of persons over 2-1/2 years of age, in accordance with section F-709.0 of the Fire Prevention Code;
 - . Individual portable kiosks or displays when erected in a covered mall for a period of less than 90 days, and when not covered by a Type 2 permit;
 - . The use of any open flame or flame producing device, in connection with any public gathering, for purposes of entertainment, amusement, or recreation;
 - . Welding and cutting operations except where the welding and cutting is performed in areas approved for welding and is registered as a Type B Life Hazard use;
 - . The possession or use of explosives or blasting agents, other than model rocketry engines regulated under N.J.A.C. 12:194;
 - . The use of any open flame or flame-producing device in connection with the training of non-fire service personnel in fire suppression or extinguishment procedures;
 - . The occasional use in any building of a multipurpose room, with a maximum permitted occupancy of 100 or more for amusement, entertainment or mercantile type purposes.
0. The storage or handling of class I flammable liquids in closed containers of aggregate amounts of more than 10 gallons, but not more than 660 gallons inside a building, or more than 60 gallons, but not more than 660 gallons outside a building.
 1. The storage or handling of class II or IIIA combustible liquids in closed containers of aggregate amounts of more than 25 gallons, but not more than 660 gallons inside a building, or more than 60 gallons, but not more than 660 gallons outside a building.
 2. Any permanent cooking operation that requires a suppression system in accordance with N.J.A.C. 5:70-4.7(g) and is not defined as a life hazard use in accordance with N.J.A.C. 5:70-2.4.
 3. The use as a place of public assembly, for a total of not more than 15 days in a calendar year, of a building classified as a commercial farm building under the Uniform Construction Code.
 4. The temporary use of any building or portion thereof as a special amusement building for a total of not more than 15 days in a calendar year.
 5. The erection, operation, or maintenance of any tent, tensioned membrane structure, or canopy, excluding those used for recreational camping purposes, that meets the criteria in (a)3xvi(1) or (2) below shall require a Type 1 permit. Tents, tensioned membrane structures, or canopies greater than 16,800 square feet in area and greater than 140 feet in any dimension, whether one unit or composed of multiple units; remaining in place for more than 180 days; used or occupied between December 1 and March 31; having a permanent anchoring system or foundation; or containing platforms or bleachers greater than 11 feet in height shall be subject to the permitting requirements of the Uniform Construction Code (N.J.A.C. 5:23-2.14).
 - (1) The tent, tensioned membrane structure, or canopy is greater than 900 square feet and more than 30 feet in any dimension whether it is one unit or composed of multiple units, but 16,800 square feet or less in area and 140 feet or less in any dimension, whether it is one unit or composed of multiple units.
 - (2) The tent, tensioned membrane structure, or canopy contains platforms or bleachers 11 feet or less in height;